

11/05/2003 16:24

5807952333

Electrical Investigator

PAGE 03

2401 N.W. 23, Suite 5  
Oklahoma City, OK 73107  
Bertw@health.state.ok.us

Office: (405) 271-5217  
Fax: (405) 271-5254  
Cell: (405) 919-1139

Dale Vermillion  
1-25-2013

October 28, 2003

To: Richard Winlock  
From: Bert Wiens State Electrical Inspector  
Re: Reada Cable

Richard,

As per our conversation, "Can Reada Cable be used outside the scope of its intended use: down hole?" According to the NFPA National Electrical Code 2002 Edition (N.E.C. 2002) **Article 110.3(B)**:

**Installation and Use.** *Listed or labeled equipment shall be installed and used in accordance with any instruction included in the listing or labeling.*

The Reada Cable company does not want this particular cable to be listed. After researching the U. L. White Book it was found that this is not a listed wiring method outside the perimeters of it's intended use.

Therefore, if this cable is used for any purpose other than "down hole use" the installer is in violation of the N.E.C. I hope I have been of some help in this matter. Please feel free to call on me again.

Thank you,

*Bert Wiens*

Bert Wiens

Missing from web  
- add to chart

Gary Williamson  
405 659 2916

12000  
10000  
10000  
2000  
5000